



The Honorable
Felix P. Camacho
Governor

The Honorable
Michael W. Cruz, M.D.
Lieutenant Governor



ROUTE 7A PAVEMENT REHABILITATION & SAFETY PROJECT
Project No. GU-NH-007A(001)

March 4, 2010

ADDENDUM NO. 5

This addendum shall form part of the Contract Documents. Pursuant to Guahan Law, failure by any proposer to acknowledge receipt of this addendum in its proposal shall be grounds for disqualification of its proposal.

Pre-Bid Questions

- RFI submitted by International Bridge & Construction Marianas, Inc., dated March 2, 2010:

Question: Regarding Item Number 60203-0200, 6 inch Slotted Drain as shown in Addendum No. 3: Is 6" the slot opening height of the neck and distance of spacer plates? Not the diameter of the corrugated slotted drain pipe? Minimum diameter in the market is 12" Diameter per suppliers

Response: Item 60203-0200 is deleted from the project by this addendum.

Question: Where is the location of the slotted drain pipes and kindly provide the lean concrete backfill minimum requirement.

Response: Item 60203-0200 is deleted from the project by this addendum. If needed for utility relocation, lean concrete backfill shall be provided in accordance with FP03 Specification Section 614. The cost for the lean concrete backfill shall be included with and considered incidental to the utility relocation.


Contract bid documents and specifications:

Deleted	Replaced With	Description
BS-7(AD-4)	BS-7(AD-5)	Deleted Item 60203-0200

The following drawing has been revised:

Drawing T-04, Sheet 4 of 48 – Deleted Item 60203-0200

- END OF ADDENDUM -


ANDREW S. LEON GUERRERO
 Acting Director

I CONCUR Date: 3/4/10
Abraham Wong
FHWA Division Administrator

By: 
Richelle M. Takara, PE
Transportation Engineer

Project Title: ROUTE 7A PAVEMENT REHABILITATION & SAFETY PROJECT
 Project Number: GU-NH-007A(001)
 Location: HAGATNA

BID SCHEDULE					
Pay Item number	Description (With Unit Bid Price in Words)	Unit	Estimated Quantity	Unit Bid Price	Bid Amount
60201-0800	24 Inch Pipe Culvert	LNFT	766	\$	\$
60201-0900	30 Inch Pipe Culvert	LNFT	955	\$	\$
60201-1000	36 Inch Pipe Culvert	LNFT	375	\$	\$
60401-0000	Manhole	EACH	19	\$	\$
60403-0000	Inlet	EACH	2	\$	\$
60403-0600	Inlet, Type 2, Double Grate	EACH	41	\$	\$

